General Electrodynamics Corporation Aircraft Scale Evaluation

Specific data can not be provided per Boeing Procedure PRO-3439; <u>Release of Information Outside The Boeing Company</u>

Performance Summary

- A calibration of the GEC AN60-6, 60,000 lb capacity portable aircraft platform scale was performed prior to beginning any tests.
- The scale performed within the specification range of +/- 0.1% of reading during the following tests:
 - o With respect to temperature at ambient, 98 deg F, and 44 deg F
 - o Uneven surface load test simulating a 14 degree slope
 - o A Corner load test in each quadrant of the scale
- Following the above series of tests, a final verification of the scale calibration was taken and the scale performed within the specification of +/- 0.1% of the applied load
- Unit meets or exceeds Boeing criteria for portable aircraft weighing platform scales and performed within the accuracy and repeatability specifications of Boeing Puget Sound Metrology.

J. T. Medina
Puget Sound Metrology
Force & Loads Laboratory - Boeing Field
3-801, col. D5, M/C 1J-89
(206) 655-5992